



**County Waterworks District No. 8
City of Simi Valley**

2929 Tapo Canyon Road, Simi Valley, California 93063 (805) 583-6700

November 26, 2019

**SUBJECT: STRATHEARN PLACE-ARROYO SIMI SEWER LINE REHABILITATION
PROJECT, SPECIFICATION NO. SV 19-09
ADDENDUM NO. 1**

All Prospective Proposers:

NOTICE IS HEREBY GIVEN to all prospective bidders that the modifications as described in the attached addendum are made to the subject project specifications.

Acknowledgment of this addendum by returning the signed addendum to the City is required. Failure to do so may result in the disqualification of your proposal.

Questions regarding this addendum may be directed to me at (805) 583-6833.

Sincerely,

Jamshed Yazdani
Associate Engineer

Attachments

**RECEIPT OF THIS NOTICE IS HEREBY ACKNOWLEDGED. PLEASE FAX OR
E-MAIL A SIGNED COPY OF THIS PAGE TO JAMSHED YAZDANI AT
(805) 583-7951, OR jyazdani@simivalley.org**

Company Name and Authorized Representative

Print: _____

Signature: _____

Title: _____

CITY OF SIMI VALLEY

STRATHEARN PLACE-ARROYO SIMI SEWER LINE REHABILITATION PROJECT,

SPECIFICATION NO. SV 19-09

ADDENDUM NO. 1

November 26, 2019

REVISED PLANS

The following revisions as noted herein:

Affected Plan Sheets	Plan Sheet Number
Plan Sheet No. C-7, C-8, and C-9.....	11-13

Change 1: Plan Sheet No.: C-7, C-8, and C-9 - Construction Note No. 8

CIPP sewer line liner may be installed in lieu of Spiral Wound PVC Liner. Installation of CIPP liner shall follow specification Section 1004-1, Section 1005, and Section 1007.

NOTE: Spiral Wound PVC Liner shall NOT be used in lieu of CIPP sewer line rehabilitation shown on other plan sheets.