



NOTES:

1. CONCRETE ENCASEMENT SHALL BE USED WHEN COVER IS LESS THAN 3 FEET.
2. ENCASEMENT TO BE PLACED AGAINST UNDISTURBED NATURAL GROUND OR FILL COMPACTED TO 90% RELATIVE COMPACTION, UNLESS OTHERWISE SPECIFIED.
3. #4 STEEL REINFORCING BARS SHALL BE USED AS SPECIFIED.
4. TYPE OF CONCRETE ENCASEMENT TO BE USED WILL BE SHOWN ON PLANS TO MEET FIELD CONDITIONS.
5. WHERE SLOPE TRENCHES ARE USED, WALLS WILL NOT BEGIN TO SLOPE CLOSER THAN 12 INCHES FROM THE TOP OF THE PIPE.
6. ENCASEMENT CONCRETE TO BE 450-C-2500, USE 560-C-3250 WITH REINFORCEMENT.
7. BACKFILL SHALL COMMENCE WHEN THE CONCRETE STRENGTH IS 75% OF THE SPECIFIED STRENGTH.

APPROVED:

/S/

DIRECTOR OF PUBLIC WORKS
Aug 28, 2006
DATE

CITY OF
SIMI VALLEY

DEPARTMENT OF PUBLIC WORKS

STANDARD CONCRETE
ENCASEMENT TYPE A, B, & C

STANDARD PLAN NO.

SV 40-60

SHEET 1 OF 1