



NOTES:

1. MINIMUM SLOPE FOR SEWER LATERALS SHALL BE ¼ INCH PER FOOT CONTINUOUSLY.
2. L= WIDTH OF UTILITY PLUS EXTENSION AT BOTH SIDES TO FIRST PIPE JOINT AT OR BEYOND TRENCH.
3. PROVIDE 15# ROOFING FELT PAPER AROUND PIPE PRIOR TO CONCRETE POUR.
4. TYPE II CROSSING NOT PERMITTED OVER WATERLINES. SEE CITY OF SIMI VALLEY STANDARD PLAN SV 40-10.
5. TYPE II CROSSING NOT PERMITTED WHEN OTHER METHODS ARE WORKABLE.

APPROVED:

/S/

DIRECTOR OF PUBLIC WORKS
Aug 28, 2006
DATE

CITY OF
SIMI VALLEY

DEPARTMENT OF PUBLIC WORKS

SEWER HOUSE LATERAL
AT UTILITY INTERSECTION

STANDARD PLAN NO.

SV 40-220

SHEET 1 OF 1